

Reader A (in) and Reader B (out) is wired the same.
 +12v - VCC
 0v/GND - GND
 Data/D0 - DAT
 Clock/D1 - CLK

ACT 1030 Configuration Configuration - Devices Select device & readers

Reader A	
Door_1_A	
Validation Mode (offline):	Only in archive pass
Reader type:	NAL
Bus Type:	Magnetic Stripe
Frequency:	125KHz
Ignore mode:	Last media (on the same readers)
Ignore Time (sec):	1
Comparison Mask:	00000000000000000000000000000000 00000000000000000000000000000000

