



Door Manager Configuration FAAC Spinet Readers Configuration - Devices Select device & readers

Reader A

Door_1_A

Validation Mode (offline): Only in archive pass

Reader type: FAAC

Bus Type: SPinet

Frequency: 125kHz

Ignore mode: Last media (on the same readers)

Ignore Time (sec): 1

Comparison Mask:

Default Setting
Reader In - Reader A
Reader Out - Reader B

Relay 1 - Lock
Relay 2 - Door Alarm

Relay Time - 5secs

IN1 - Lock Monitor
IN2 - Request to Exit Device
IN3 - BGU Monitor